

FIRE NOC APPLICATION

Application ID/ Application Identification Number	LSG/SRI GANGANAGAR/FIRE NOC/2023- 24/20042	Applied Date/ Application Date	17-04-2024
--	---	-----------------------------------	------------

Applicant/NOC Details/ Applicant/NOC Details

District Name/ district	Sri Ganganagar
ULB Name/ Urban Local Bodies	SRI GANGANAGAR.
Zone/ Zone	ZONE ALL

Applicant Details

First Name name	LINCY
Last Name/ Surname	C L
Father's Name/ Father's Name	CO LONAPPAN
Mobile No./ Mobile Number	9694396944
Email/Mail email	10491@CBSESHIKSHA. IN
Address/ addre	SACRED HEART CONVENT SCHOOL HANUMANGARH ROAD SRIGANGANAGAR

NOC Details:

Category Name/ cla	GROUP B: EDUCATIONAL
Sub Category Name Subcategory	NA
Type of NOC/ Type of NOC	Permanent
Plot Area(Square Meter) Plot Area (in sq. mtrs)	17320

Building Details/ Building Details

Building Name/ Building Name	SACRED HEART CONVENT SCHOOL
Building Number/ Number of Building	MURABBA NO 28
Lane/ Street/ Alley/Route	Cheque 6 E Peak
Locality/ Quarter or part of a town	BABA DEEP SINGH COLONY

State/ kingdom	Rajasthan
District/ district	Sri Ganganagar
Rural/ rural	NO/ No
City/ city	Sri Ganganagar
Name of Builder/ Promoter/ Name of Manufacturer/Promoter	
Building Purpose/ Building Purpose	Institutional
Building Category/ Building Category	EDUCATIONAL (PRIMARY, SECONDARY, HIGHER SECONDARY, COLLEGE, UNIVERSITY, TECHNICAL INSTITUTE)
Gross Build Up Area (Sq mt)/ Gross Construction Area (sq. mtrs)	4317.275
Gross Build Up Area (Sq. ft.)/ Gross Construction Area (sq. ft.)	46470.75954525
Plinth Area Plinth Area	46470
Height of the building(in mt.)	12
Overall height (from ground level in mt.)/ Total height (in meters from ground level)	12
Number of floors (including ground floor)/ Number of floors (including ground floor)	2
BAR/BAR Bar	1
Details of water supply available exclusively for fire fighting/ Water supply available exclusively for fire fighting	Over Head Water Tank & Under Ground Water Tank
Has Wet riser(s) been provided?/ Is a wet riser provided?	Yes
Number of Wet risers/ Number of Wet Risers	1
Wet riser diameter	100 MM
Has Dry riser(s) been provided?/ Is a dry riser provided?	No
Dry riser Details	
Has any down comer been provided?/ Is there a down comer?	Yes
Down comer Details/ Down Commer Details	100MM

Please indicate the present arrangement for replenishment of water for fire fighting/ Please refer to the present arrangement for water replenishment for fire fighting

Whether any water store available?/ Is there any water storage available? Yes

Water quantity available at Store(In KiloLiter)/ Quantity of water available at storage (in kilolitres) 50

Distance from Store/ Distance from storage 5

Hose Reel Details/ Hose Reel Description

Has internal hydrant been provided?/ Is the internal hydrant provided? No

Water quantity available at Store/ Amount of water available at storage 50

Have first add-hose reels been provided?/ Is the first ad-hose reels provided? Yes

Number of hose reels/ Number of Hose Reels 6

Length of hose-reel/ Hose-reel length 30 m

Size of nozzle fitted to hose-reel/ Size of nozzle mounted in hose-reel (in mm) 20

Type of nozzle fitted to hose-reel/ Type of nozzle mounted in hose-reel Hand Controlled

Is the hose reel connected directly to the riser or to the hydrant outlet?/ Is the hose reel directly connected to the riser or to a hydrant outlet? Yes

Has fire hose been provided near each hydrant?/ Is a fire hose provided near each hydrant? Yes

Type of hose/ Hose Type Lined

The length of each hose(in Meter)/ Length of each hose (in meters) 30

Total number of hoses provided/ Total number of hoses provided	6
Have branch pipes been provided?/ What put pipes are provided?	NA
Type of Branch Pipe Type of Putting Pipe	
Size of nozzle fitted to Branch Pipe(in MM)/ Size of nozzle mounted in put pipe (in mm)	20
Has it been sprinkled?/ Has it been sprayed?	No

Other Details/ Other Information

System Details:/ System Description:

Is the building equipped with automatic fire detection and alarm system?/ Is the building equipped with automatic fire detection and alarm systems?	Yes
Type of detectors used/ Types of detectors used	SMOOK
Code to witch the installation confirms/ Code that confirms installation	NA
Standard to which the detectors confirm/ Standard for which detectors confirm	
Have manual call boxes been installed in the building for raising an alarm in the event of an outbreak of fire?/ Are there manual call boxes installed in the building to sound an alarm in case of a fire?	Yes
Manual call boxes details/ Manual Call Box Description	MAFAS
Has public address system been provided between the various floors and the fire control room in entrance lobby?/ Is the public address system provided between the different floors in the entrance lobby and the fire control room?	NA
Has an intercom system been provided between the various floors and the fire	NA

control room in entrance of the building?/ Does the building entrance provide an intercom system between different floors and the fire control room?	
Has a fire control room be provided in entrance lobby of the building?/ Is a fire control room provided in the entrance lobby of the building?	NA
How many staircases have been provided in the building?/ How many stairs are provided in the building?	8
Width of the stairway/ Ladder width (in inches)	48
Width of the treads/ Step width	11
Height of the riser(in Meter)/ Riser height (in meters)	6
If the treads are of the non-slip type ?/ If the steps are non-slip type?	Yes
What is the average occupant load per floor?/ What is the average occupant load per floor?	120
How many lifts have been installed in the building?/ How many lifts are installed in the building?	0
The floors between which the lift runs/ Floors between which the elevator runs	0
The type of doors fitted to the lift car and at each landing/ Types of elevator cars and doors mounted on each landing	
Fire resistance rating of lift car and landing doors, if known/ Fire resistance rating of elevator car and landing doors, if known	
Floor area of the lift car(in Square Meter)/ Floor area of lift car (in square meters)	
Loading capacity of the lift car(In Person)/ Loading capacity of lift car (in person)	

Loading capacity of the lift car(In Kg)/ Loading capacity of lift car (in kg)	
Has communication system been installed in the lift car?/ Is the communication system installed in the lift car?	No
Has a fireman's switch been installed in the lift for grounding it in the event of fire?/ Is the fireman's switch installed for grounding in case of fire in the lift?	No
<u>Other Building Details:/ Other Building Details:</u>	
Have any stationary fire pump(s) been installed for pressurizing the wet riser?/ Are there any stationary fire pumps installed to pressurize the wet riser?	Yes
Size of suction and delivery connection of each pump/ प्रत्येक पंप के खिंचाव और वितरण कनेक्शन का आकार	100 MM
Number of Main pumps/ मुख्य पंपों की संख्या	1
The output of Main pump(LPM)/ मुख्य पंप (एलपीएम) का उत्पादन	450
Number of Joky pumps/ जॉकी पंपों की संख्या	0
The output of Joky pump(LPM)/ जॉकी पंप (एलपीएम) का आउटपुट	0
Number of Diesel/Generator pumps/ Number of diesel/generator pumps	0
The output of Diesel/Generator pump(LPM)/ Production of Diesel/Generator Pump (LPM)	0
The maximum head against which the pump can operate at the output/ The maximum head against which the pump can operate at the output	450
Is the pump automatic in action?/ Is the pump functioning automatically?	Yes
Has a standby source of power supply been provided?/ Is an additional source of power supply provided?	Yes
Capacity/ competence	5

<p>The function that can be maintained simultaneously by the use of generator, such as operating life(s) fire pumps emergency lighting etc./ Functions that can be maintained simultaneously with the use of generators, such as the operation of fire pumps, emergency lighting, etc.</p>	<p>Yes</p>
<p>Is the generator automatic in action or has to be started manually?/ Is the generator acting automatically or has to be started manually?</p>	<p>Yes</p>
<p>Has any yard hydrant been provided form the building's fire pump?/ Is there any yard hydrant provided from the building's fire pump?</p>	<p>NA</p>
<p>Where more than one lifts are installed in a common enclosure have individual lift been separated by fire resisting walls or 2 hours fire rattooing?/Where more than one lift is installed in a normal enclosure, are the individual elevators separated by fire resistant walls or 2 hours fire rattooing?</p>	<p>NA</p>
<p>Has the lift shaft(s) lift lobby or stairwell been pressurized?/ Is the elevator shaft(s) pressurized on the elevator lobby or staircase?</p>	<p>NA</p>
<p>Lift lobby details:/ Elevator Lobby Description:</p>	
<p>Have the lift lobbies and staircase been effectively enclosed to prevent fire/smoke entering them from outside at any floor?/ Are elevator lobbies and stairs effectively enclosed on any floor to prevent fire/smoke from entering from outside?</p>	<p>NA</p>
<p>Have all exits and direction of travel to each exit been sign-posted with illuminated signs?/ Is all exit directions signed-post with published signs for each exit?</p>	<p>NA</p>

Has a false ceiling been provided in any protection of the building?/ Does any safety of the building provide false ceiling?	NA
If so, please indicate location false Ceiling Material Type/ If so, please indicate the location of the false ceiling and the type of material used	
Material used for the false ceiling is combustible or non-combustible/ The material used for false ceiling is combustible or non-combustible	No
Is the building centrally air conditioned?/ Is the building centrally air-conditioned?	NA
Material used for construction of duct and its fittings/ Materials used for the manufacture of duct and its fittings	
Type of tinning use for duct/ Type of tinting use for duct	
Type of lagging used/ Type of lagging used	
Type of tinning use for duct/ Type of tinting use for duct	
If any for insulating any portion of the duct, please also indicate how the lagging is secured/ While insulating any part of the duct, please also explain how the lagging is safe	
False ceiling details/ False Ceiling Details	
Has a separate AHU been provided for each floor?/ Is a separate AHU provided for each floor?	No
If plenum is used a return air passage has it been protected with fire detectors?/ If plenum is used, the return air passage is protected with fire detectors?	No
<u>Fire Extinguishing Details:/ Description of Fire Extinguisher:</u>	
Where are the switchgear and transformers located?/ Where are the switchgear and transformer located?	NA

<p>If the switchgear and transformer(s) have been housed in separate compartments, effectively separated from each other and from other portion of the building by a four hours fire resistive wall?/ What if the switchgear and transformers are placed in separate compartments, effectively separated by a four-hour fire-resistant wall from each other and from another part of the building?</p>	<p>NA</p>
<p>What precautions have been taken to prevent a possible fire in the transformer(s) from spreading?/ What precautions have been taken to prevent possible fire from spreading to transformers?</p>	<p>ABC</p>
<p>Whether electric cables, telephone cables, dry/wet risers/down comers pass through a floor or wall have the spaces(apertures) round the cables/pipes been effectively sealed/plugged with non-combustible, fire resistant material?/ Do electrical wires, telephone cables, dry/wet risers/down commerce pass through the floor or wall, are the spaces (apertures) around the cable/pipe effectively plugged with sealed/non-combustible, fire-resistant material?</p>	<p>NA</p>
<p>Please indicate the number of fire extinguishers provided?/ Please tell the number of fire extinguishers provided?</p>	<p>25</p>
<p>Please indicate if all fire extinguishers bear the ISI certification mark/ Please indicate if all fire extinguishers bear ISI certification mark</p>	<p>ISI</p>
<p>Please indicate the type of fire extinguishers provided?/ Please tell us what kind of fire extinguishers have been provided?</p>	<p>ABCCO2</p>
<p>Please indicate the arrangement for the maintenance of the extinguishers/</p>	<p>MONTHLY</p>

Please mention the arrangement for maintenance of fire extinguishers	
Whether the refuge area has been provided?/ Is the refuge area provided?	NA
Refuge area details/ Description of Refuge Area	G
Does an emergency organization exist in the building?/ Are there any emergency organizations in the building?	NA
Emergency Organization details Emergency Organization Details	
Has the building been protected against lightening?/ Has the building been saved from lightning?	NA
Does the lightening protect confirm to any code? Please indicate/ Does Lightning Protect confirm any code? Please show	
Are the occupants of the building systematically trained in fire prevention?/ Are building occupants systematically trained to prevent fires?	NA
Has a qualified fire officer been appointed for the building either individually or jointly with other building(s)/ Whether a qualified fire officer has been appointed for the building individually or jointly with other buildings	NA



Document Uploads Details Uploaded document details

Id Proof ID proof

Buiding Photo/ Skyscraper/ Plot Photo

Ownership/ ownership

Affidavit Sworn Characters

UD Tax Receipt/ UD Tax Receipt

Fire Plan/ Fire Plan

 Audit Trail/ Audit Trail

S.No.	ACTION TAKEN BY	ACTION TAKEN ON	ACTION TAKEN	STATUS	DOCUMENT
1	HUGE. GUMBER1989	17-04-2024	APPLICATION SUBMITTED	APPLICATION SUBMITTED AND PENDING WITH DC FIRE/EO/COMMISSIONER	
2	RJBI199809004542	18-04-2024	TAKE ACTION AND GIVE REPORT	PENDING WITH DA (DOCUMENT CHECK)	
3	RAJ. KUMAR19811	18-04-2024	YOUR APPLICATION CHECKED OWNER NAME WRONG . PLEASE COMPLETE YOUR APPLICATION AND COME UP AGAIN	PENDING WITH APPLICANT CLARIFICATION RAISED BY DA	
4	HUGE. GUMBER1989	18-04-2024	APP UPDATE	PENDING WITH DA CLARIFICATION RECEIVED BY APPLICANT	
5	RAJ. KUMAR19811	18-04-2024	YOUR APPLICATION CHECKED FOR WORD FOR F O SITE INSPECTION	PENDING WITH DC FIRE/EO/COMMISSIONER AFTER DA SCRUTINY	
6	RJBI199809004542	18-04-2024	INSPECT THE SITE	PENDING WITH FIRE OFFICER SITE INSPECTION	